

Smart Accumulator with Oil Circulation Ratio Sensing

Track Code: 2021-GROL-69502

Categories:

- Mechanical Engineering

Keywords:

- Compressor
- Mechanical Engineering
- Oil Circulation
- Oil Circulation Ratio
- Refrigeration

Researchers at Purdue University have developed a new method to determine oil circulation in refrigeration systems that employ lubricated compressors. Oil lubricates the bearings and other contact surfaces in compressors. The current method to measure oil circulation ratio (OCR) involves transferring solvent and oil out of the system. Practically, it's impossible to measure more than 3-4 samples at a time using this method. The Purdue researchers' method determines OCR in-situ. The method also allows multiple samples of oil to be taken in succession, allowing the low frequency dynamic behavior of OCR to be distinguished. Additionally, by separating the solvent and oil flows, the method is able to measure OCR for immiscible refrigerant/lubricant pairs. The OCR values predicted by the researchers' method were within 12% of the values predicted by the ASHRAE standard method. Finally, with a smart accumulator, the system protects the compressor from liquid flooding and oil starvation.

Advantages

- &V Â×F-ÖP
- "-â×6—GP
- " WFöÖ FV@
- "Ö-æ-Ö—|W2 ‡VÖ â W'&÷
- "FöW2 æ÷B &W V—&R 6 Æ-'& F-öà
- "6öçF-çV÷W2 ÷ W& F-öà

Applications

- "ÖV 7W&-æ" ô5" -â &Vg&-vW& F-öâ 7—7FV×2 V× Æöyng lubricated compressors

Technology Validation: The method was experimentally validated with the ASHRAE standard method, a standard method to measure OCR.

Related Publication:

Shah VM, Braun JE, PhD., Groll EA, PhD. Measuring oil retention in unitary split system gas

lines. ASHRAE Trans. 2021;127:327-336.

People:

- Groll, Eckhard Achim (Project leader)
- Braun, James Edward
- Dhillon, Parveen
- Kurtulus, Orkan
- Shah, Vatsal Manilal

Intellectual Property:

Application Date: May 31, 2022

Type: Utility Patent

Country of Filing: United States

Patent Number: (None)

Issue Date: (None)

Application Date: June 4, 2021

Type: Provisional-Patent

Country of Filing: United States

Patent Number: (None)

Issue Date: (None)

Contact OTC:

Purdue Office of Technology Commercialization
The Convergence Center
101 Foundry Drive, Suite 2500
West Lafayette, IN 47906

Phone: (765) 588-3475

Fax: (765) 463-3486

Email: otcip@prf.org